From: Smith, Monica

To: Adams, Adam; Mason, Steve

Subject: this is an example of the update ronnie provided today

Date: Monday, March 18, 2019 4:08:52 PM

Attachments: 2019-03-18 International Terminals Corporation Update.docx

Monica Smith Chief, Planning, Prevention, Readiness & Response Section (6SF-EA) 214-665-6780 office 469-766-3398 cell smith.monica@epa.gov

From: Crossland, Ronnie

Sent: Monday, March 18, 2019 11:52 AM **To:** Gray, David <gray.david@epa.gov>

Cc: Edlund, Carl <Edlund.Carl@epa.gov>; Smith, Monica <smith.monica@epa.gov>

Subject: International Terminal Corporation Fire

David,

Here is the update. We are waiting on data package from ASPECT to share with TCEQ. Will provide additional information as it comes available

Ronnie

International Terminals Corporation (ITC) Fire Update Deer Park, Texas March 18, 2019

- At approximately 10:20 am local time on March 17, 2019, Intercontinental Terminals Corporation (ITC) discovered a tank on fire and reported the incident to the National Response Center (NRC #1240304). EPA Region 6 Phone Duty Officer (PDO) activated the Response Duty Officer (RDO) and EPA START contractors to respond.
- EPA mobilized and entered Unified Command with TCEQ, Harris County Pollution Control Services, and ITC. USCG also mobilized and is providing support.
- Predominant winds were from the east northeast from La Porte, Texas towards Hobby
 Airfield. EPA and ITC continued air monitoring throughout the night in the vicinity and
 downwind. Particulates were detected just southwest of the facility, but no readings above
 action levels. No readings of VOCs or other constituents were detected.

- EPA conducted aerial air monitoring with the use of the ASPECT aircraft and measured no significant detections in the vicinity and downwind of the incident.
- As of 0500 hours on 03/18, 9 tanks containing gasoline blends, toluene, naphtha, xylenes, pyrolysis gasoline, and blended oils were involved in the fire. The shelter in place for the City of Deer Park is still in effect. Highway 225 continues to be closed in both directions in the vicinity of the facility.
- Emergency responders continue to use foam to control the fire and prevent the fire from spreading to the remaining tanks within the contained area. We are checking on the type of foam being deployed. The RP said it did not contain PFAS.
- At 5:30 am on 3/18/19, the City of Deer Park lifted the shelter-in-place order. http://www.ci.deer-park.tx.us/CivicAlerts.aspx?AID=979
- Deer Park and La Porte ISDs canceled class for today (3/18/19) https://www.lpisd.org/
- The TAGA has been requested and will depart RTP, North Carolina, this morning (3/18/19). It is expected to be on scene on Wednesday (3/20/19).